

**Follow-up Inspection for Asbestos Containing Materials
Greenville County Health Department Buildings
200 University Ridge
Greenville, S.C. 29601**

Prepared for:

*Mr. Perry Swearingen
Greenville County
301 University Ridge
Greenville, S.C. 29601-3660*

by:

ENVIRONMENTAL TESTING & MANAGEMENT, INC.

**Follow-up Inspection for Asbestos Containing Materials
Greenville County Health Department Buildings
200 University Ridge
Greenville, S.C. 29601**



Table of Contents

<u>Tab</u>	<u>Contents</u>
1.	Inspection Report - Original Building
2.	Inspection Report - 4 story tower building
3.	Laboratory Report - add-on building

**Follow-up Limited Inspection for Asbestos Containing Materials
Greenville County Health Department
Original Building
200 University Ridge
Greenville, S.C. 29601**

Prepared for:

***Mr. Perry Swearingen
Greenville County
301 University Ridge
Greenville, S.C. 29601-3660***

May 23, 2012

Prepared by:

Environmental Testing and Management, Inc.

P.O. Box 896
Mauldin, South Carolina 29662
Phone (864) 213-4408 Fax (864) 213-4409

**Follow-up Limited Inspection for Asbestos Containing Materials
Greenville County Health Department - Original Building
200 University Ridge
Greenville, S.C. 29601**

I. Introduction

Environmental Testing and Management Inc., (ETM) was retained by Mr. Perry Swearingen of Greenville County to conduct a limited follow-up inspection for suspect asbestos containing materials in the Greenville County Health Department building, located at 200 University Ridge, Greenville, S.C. The Health Department consists of three distinct areas, each built at a different time. This inspection focused on replacement ceiling tiles in the original building not sampled during the April 9th inspection. Also, additional samples of plaster were collected. The April 9th site inspection collected sufficient samples based upon the amount of material to be impacted as a consequence of the fire alarm system upgrade work. However, DHEC would like the number of samples collected to be based upon the total square footage of the plaster located in places throughout the building. Thus this second inspection was conducted by Andrew Schauder, CIH, and Roxane Schauder, MS, of ETM on May 12, 2012. Nine (9) bulk materials were collected and (12) layers were analyzed for the presence of asbestos.

II. Observations

The inspection began in the basement hallway. Samples (1-3) were collected of the only type of replacement ceiling tiles present in this area. On the 2nd floor, another type of replacement ceiling tiles was observed and three samples (6-8) were collected of these tiles. All samples returned as negative for the presence of asbestos.

Two samples (4-5) of plaster (base coat and skim coat) were collected on the 1st floor while a third sample (9) was collected on the 2nd floor. All returned as negative for the presence of asbestos.

III. Conclusions and Recommendations

The results of this survey are summarized in Table I. This Table lists the following data:

1. Sample number
2. Sample location
3. Material sampled
4. The result of the analysis of the material sampled.

*Follow-up Limited Inspection for Asbestos Containing Materials
Greenville County Health Department - Original Building
200 University Ridge
Greenville, S.C. 29601
Page Two*

As noted above, all samples collected were negative for the presence of asbestos.

A total of four different types of ceiling tiles are in the original building, the two main types originally sampled and the replacement types that are the focus of this survey. All were found to be negative for the presence of asbestos.

A total of seven samples have now been collected of the plaster present in various spots in the original building. Samples collected during the April 9th survey include two on the 1st floor and two on the 2nd floor. During the May 12th visit, three additional samples were collected; two on the 1st floor and one on the 2nd floor. All samples returned as negative for the presence of asbestos.

Inspector:

Roxane Schauder

License: #1336 Expires: 09/21/12

Inspector:

Roxane Schauder

License: #00189 Expires: 02/16/13

Follow-up Limited Inspection for Asbestos Containing Materials
Greenville County Health Department - Original Building
200 University Ridge
Greenville, S.C. 29601
Page Three

TABLE I

Sample No.	Location Sampled	Material	Result
01 - 03	Basement hallway	Ceiling tiles	ND*
04 - 05	1 st Floor	Plaster	ND*
06 - 08	2 nd Floor	Ceiling tiles	ND*
09	2 nd Floor	Plaster	ND *

ND*: none detected



ASBESTOS LABORATORY REPORT

Prepared for

Environmental Testing & Management, Inc.

PROJECT: Greenville County - Health Department - Original Bldg.

CEI LAB CODE: A12-4282

DATE REPORTED: 05/21/12

TOTAL SAMPLES ANALYZED: 9

SAMPLES >1% ASBESTOS:

TEL: 866-481-1412

www.ceilabs.com



Asbestos Report Summary

By: POLARIZING LIGHT MICROSCOPY

PROJECT: Greenville County - Health Department - CEI LAB CODE: A12-4282
Original

METHOD: EPA 600 / R93 / 116 and EPA 600 / M4-82 / 020

Client ID	Layer	Lab ID	Color	Sample Description	ASBESTOS %
1		A1290940	Off-white	Ceiling Tile	None Detected
2		A1290941	Off-white	Ceiling Tile	None Detected
3		A1290942	Off-white	Ceiling Tile	None Detected
4	Layer 1	A1290943	White	Plaster Skim Coat	None Detected
	Layer 2	A1290943	Grey	Plaster Base Coat	None Detected
5	Layer 1	A1290944	White	Plaster Skim Coat	None Detected
	Layer 2	A1290944	Grey	Plaster Base Coat	None Detected
6		A1290945	Off-white	Ceiling Tile	None Detected
7		A1290946	Off-white	Ceiling Tile	None Detected
8		A1290947	Off-white	Ceiling Tile	None Detected
9	Layer 1	A1290948	White	Plaster Skim Coat	None Detected
	Layer 2	A1290948	Grey	Plaster Base Coat	None Detected



ASBESTOS BULK ANALYSIS

By: POLARIZING LIGHT MICROSCOPY

Client: Environmental Testing & Management, Inc.
 P.O. Box 896
 Mauldin, SC 29662

CEI Lab Code: A12-4282
Date Received: 05-16-12
Date Reported: 05-21-12

Project: Greenville County - Health Department - Original Bldg.

ASBESTOS BULK PLM, EPA 600 METHOD

Client ID Lab ID	Lab Description	Lab Attributes	NON-ASBESTOS COMPONENTS			ASBESTOS %
			Fibrous	Non-Fibrous		
1 A1290940	Ceiling Tile	Heterogeneous	40%	Cellulose	30%	None Detected
		Off-white Fibrous Bound	25%	Fiberglass	5%	
2 A1290941	Ceiling Tile	Heterogeneous	40%	Cellulose	30%	None Detected
		Off-white Fibrous Bound	25%	Fiberglass	5%	
3 A1290942	Ceiling Tile	Heterogeneous	40%	Cellulose	30%	None Detected
		Off-white Fibrous Bound	25%	Fiberglass	5%	
4 Layer 1 A1290943	Plaster Skim Coat	Heterogeneous			50%	None Detected
		White Non-fibrous Bound			50%	
Layer 2 A1290943	Plaster Base Coat	Heterogeneous			50%	None Detected
		Grey Non-fibrous Bound			50%	
5 Layer 1 A1290944	Plaster Skim Coat	Heterogeneous			50%	None Detected
		White Non-fibrous Bound			50%	
Layer 2 A1290944	Plaster Base Coat	Heterogeneous			50%	None Detected
		Grey Non-fibrous Bound			50%	
6 A1290945	Ceiling Tile	Heterogeneous	40%	Cellulose	30%	None Detected
		Off-white Fibrous Bound	25%	Fiberglass	5%	



ASBESTOS BULK ANALYSIS

By: POLARIZING LIGHT MICROSCOPY

Client: Environmental Testing & Management, Inc.
 P.O. Box 896
 Mauldin, SC 29662

CEI Lab Code: A12-4282

Date Received: 05-16-12

Date Reported: 05-21-12

Project: Greenville County - Health Department - Original Bldg.

ASBESTOS BULK PLM, EPA 600 METHOD

Client ID Lab ID	Lab Description	Lab Attributes	NON-ASBESTOS COMPONENTS				ASBESTOS %
			Fibrous		Non-Fibrous		
7 A1290946	Ceiling Tile	Heterogeneous	40%	Cellulose	30%	Perlite	None Detected
		Off-white Fibrous Bound	25%	Fiberglass	5%	Paint	
8 A1290947	Ceiling Tile	Heterogeneous	40%	Cellulose	30%	Perlite	None Detected
		Off-white Fibrous Bound	25%	Fiberglass	5%	Paint	
9 Layer 1 A1290948	Plaster Skim Coat	Heterogeneous			50%	Binder	None Detected
		White Non-fibrous Bound			50%	Calc Carb	
Layer 2 A1290948	Plaster Base Coat	Heterogeneous			50%	Binder	None Detected
		Grey Non-fibrous Bound			50%	Silicates	

**Follow-up Limited Inspection for Asbestos Containing Materials
Greenville County Health Department
4 Story Tower
200 University Ridge
Greenville, S.C. 29601**

Prepared for:

***Mr. Perry Swearingen
Greenville County
301 University Ridge
Greenville, S.C. 29601-3660***

May 23, 2012

Prepared by:

Environmental Testing and Management, Inc.

P.O. Box 896
Mauldin, South Carolina 29662
Phone (864) 213-4408 Fax (864) 213-4409

**Follow-up Limited Inspection for Asbestos Containing Materials
Greenville County Health Department - 4 Story Tower
200 University Ridge
Greenville, S.C. 29601**

I. Introduction

Environmental Testing and Management Inc., (ETM) was retained by Mr. Perry Swearingen of Greenville County to conduct a limited follow-up inspection for suspect asbestos containing materials in the Greenville County Health Department building, located at 200 University Ridge, Greenville, S.C. The Health Department consists of three distinct areas, each built at a different time. This inspection focused on replacement ceiling tiles in the 4 story tower not sampled during the April 9th inspection. This inspection was conducted by Andrew Schauder, CIH, and Roxane Schauder, MS, of ETM on May 12, 2012. Seven (7) bulk materials were collected and analyzed for the presence of asbestos.

II. Observations

The inspection began in the basement hallway. Samples (1-3) were collected of one type of replacement ceiling tiles present in this area while samples (4-6) were collected of another. These samples all returned negative for the presence of asbestos. The same types of ceiling tiles were found throughout the building.

A single sample (7) was collected of spray-applied fireproofing. During the April 9th survey, no samples were collected on the third floor due to the space constraints in the area available for sampling. During the May 12th inspection, a sample of spray-applied was collected in the third floor lobby. As was the case with the spray-applied samples collected April 9th, this sample returned negative for the presence of asbestos as well.

III. Conclusions and Recommendations

The results of this survey are summarized in Table I. This Table lists the following data:

1. Sample number
2. Sample location
3. Material sampled
4. The result of the analysis of the material sampled.

*Follow-up Limited Inspection for Asbestos Containing Materials
Greenville County Health Department - 4 Story Tower
200 University Ridge
Greenville, S.C. 29601
Page Two*

As noted above, all samples collected were negative for the presence of asbestos.

A total of four different types of ceiling tiles are in the 4 story tower, the two main types originally sampled and the replacement types that are the focus of this survey. All were found to be negative for the presence of asbestos.

Eight samples of spray-applied fireproofing were collected during the April 9th visit (DHEC requires a minimum of seven). Two samples each were collected on the basement, 1st, 2nd and 4th floor levels. Samples were not collected on level 3 due to space constraints only. There is nothing to distinguish the spray-applied fireproofing on level 3 from any other level, but one sample was collected to document, once again, that the spray-applied fireproofing in this building is negative for the presence of asbestos.

Inspector: *Cop Schauder* License: #1336 Expires: 09/21/12

Inspector: *Roxane Schauder* License: #00189 Expires: 02/16/13

Follow-up Limited Inspection for Asbestos Containing Materials
Greenville County Health Department - 4 Story Tower
200 University Ridge
Greenville, S.C. 29601
Page Three

TABLE I

Sample No.	Location Sampled	Material	Result
01 - 03	Basement hallway	Ceiling tiles	ND*
04 - 05	Basement hallway	Ceiling tiles	ND*
07	3 rd floor lobby	Spray-applied fireproofing	ND*

ND*: none detected



AMENDED

ASBESTOS LABORATORY REPORT

Prepared for

Environmental Testing & Management, Inc.

PROJECT: Greenville County - Health Department - 4 Story Tower

CEI LAB CODE: A12-4284

DATE REPORTED: 05/21/12

TOTAL SAMPLES ANALYZED: 7

SAMPLES >1% ASBESTOS:

TEL: 866-481-1412

www.ceilabs.com



AMENDED

Asbestos Report Summary

By: POLARIZING LIGHT MICROSCOPY

PROJECT: Greenville County - Health Department - 4 CEI LAB CODE: A12-4284
Story Tower

METHOD: EPA 600 / R93 / 116 and EPA 600 / M4-82 / 020

Client ID	Layer	Lab ID	Color	Sample Description	ASBESTOS %
1		A1290955	White,Tan	Ceiling Tile	None Detected
2		A1290956	White,Tan	Ceiling Tile	None Detected
3		A1290957	White,Tan	Ceiling Tile	None Detected
4		A1290958	White,Tan	Ceiling Tile	None Detected
5		A1290959	White,Tan	Ceiling Tile	None Detected
6		A1290960	White,Tan	Ceiling Tile	None Detected
7		A1290961	Brown	Spray-applied	None Detected



AMENDED ASBESTOS BULK ANALYSIS

By: POLARIZING LIGHT MICROSCOPY

Client: Environmental Testing & Management, Inc.
 P.O. Box 896
 Mauldin, SC 29662

CEI Lab Code: A12-4284

Date Received: 05-16-12

Date Reported: 05-21-12

Project: Greenville County - Health Department - 4 Story Tower

ASBESTOS BULK PLM, EPA 600 METHOD

Client ID Lab ID	Lab Description	Lab Attributes	NON-ASBESTOS COMPONENTS				ASBESTOS %
			Fibrous		Non-Fibrous		
1 A1290955	Ceiling Tile	Heterogeneous	60%	Cellulose	5%	Binder	None Detected
		White, Tan	20%	Fiberglass	5%	Paint	
		Fibrous			10%	Perlite	
		Loosely Bound					
2 A1290956	Ceiling Tile	Heterogeneous	60%	Cellulose	5%	Binder	None Detected
		White, Tan	20%	Fiberglass	5%	Paint	
		Fibrous			10%	Perlite	
		Loosely Bound					
3 A1290957	Ceiling Tile	Heterogeneous	60%	Cellulose	5%	Binder	None Detected
		White, Tan	20%	Fiberglass	5%	Paint	
		Fibrous			10%	Perlite	
		Loosely Bound					
4 A1290958	Ceiling Tile	Heterogeneous	60%	Cellulose	5%	Binder	None Detected
		White, Tan	20%	Fiberglass	5%	Paint	
		Fibrous			10%	Perlite	
		Loosely Bound					
5 A1290959	Ceiling Tile	Heterogeneous	60%	Cellulose	5%	Binder	None Detected
		White, Tan	20%	Fiberglass	5%	Paint	
		Fibrous			10%	Perlite	
		Loosely Bound					
6 A1290960	Ceiling Tile	Heterogeneous	60%	Cellulose	5%	Binder	None Detected
		White, Tan	20%	Fiberglass	5%	Paint	
		Fibrous			10%	Perlite	
		Loosely Bound					
7 A1290961	Spray-applied	Heterogeneous	20%	Fiberglass	60%	Binder	None Detected
		Brown			20%	Vermiculite	
		Fibrous					
		Loosely Bound					



AMENDED

LEGEND: Non-Anth = Non-Asbestiform Anthophyllite
Non-Trem = Non-Asbestiform Tremolite
Calc Carb = Calcium Carbonate

METHOD: EPA 600 / R93 / 116 and EPA 600 / M4-82 / 020

The detection limit for the method is <1% by visual estimation and 0.25% by 400 point counts or 0.1% by 1,000 point counts.

Due to the limitations of the EPA 600 Method, nonfriable organically bound materials (NOBs) such as vinyl floor tiles can be difficult to analyze via polarizing light microscopy (PLM). EPA recommends that all NOBs analyzed by PLM, and found not to contain asbestos, be further analyzed by Transmission Electron Microscopy (TEM). Please note that PLM analysis of dust and soil samples for asbestos is not covered under NVLAP accreditation.

This report may not be reproduced, except in full, without written approval by CEI LABS. CEI LABS makes no warranty representation regarding the accuracy of client submitted information in preparing and presenting analytical results. This report may not be used by the client to claim product endorsement by NVLAP or any other agency of the U. S. Government.

ANALYST: Megan Fisher
Megan Fisher

APPROVED BY: Tianbao Bai
Tianbao Bai, Ph.D.
Laboratory Director



**Follow-up Limited Inspection for Asbestos Containing Materials
Greenville County Health Department
Original Building Addition
200 University Ridge
Greenville, S.C. 29601**

Prepared for:

***Mr. Perry Swearingen
Greenville County
301 University Ridge
Greenville, S.C. 29601-3660***

May 23, 2012

Prepared by:

Environmental Testing and Management, Inc.

P.O. Box 896
Mauldin, South Carolina 29662
Phone (864) 213-4408 Fax (864) 213-4409

**Follow-up Limited Inspection for Asbestos Containing Materials
Greenville County Health Department - Original Building Addition
200 University Ridge
Greenville, S.C. 29601**

I. Introduction

Environmental Testing and Management Inc., (ETM) was retained by Mr. Perry Swearingen of Greenville County to conduct a limited follow-up inspection for suspect asbestos containing materials in the Greenville County Health Department building, located at 200 University Ridge, Greenville, S.C. The Health Department consists of three distinct areas, each built at a different time. This inspection focused on replacement ceiling tiles in the original building addition not sampled during the April 9th inspection. Also, additional samples of sheetrock and joint compound were collected. The April 9th site inspection collected sufficient samples based upon the amount of material to be impacted as a consequence of the fire alarm system upgrade work. However, DHEC would like samples collected in additional areas. Thus this second inspection was conducted by Andrew Schauder, CIH, and Roxane Schauder, MS, of ETM on May 12, 2012. Eleven (11) bulk materials were collected and (16) layers were analyzed for the presence of asbestos.

II. Observations

The inspection began in the 1st floor lobby area. Samples (1-3) were collected of one type of replacement ceiling tiles present in this area while samples (4-6) were collected of another type. All samples returned as negative for the presence of asbestos.

Three samples (7-9) of sheetrock and joint compound were collected in the lobby while two additional samples (10-11) were collected in the hallway. All returned as negative for the presence of asbestos.

III. Conclusions and Recommendations

The results of this survey are summarized in Table I. This Table lists the following data:

1. Sample number
2. Sample location
3. Material sampled
4. The result of the analysis of the material sampled.

*Follow-up Limited Inspection for Asbestos Containing Materials
Greenville County Health Department - Original Building Addition
200 University Ridge
Greenville, S.C. 29601
Page Two*

As noted above, all samples collected were negative for the presence of asbestos.

A total of four different types of ceiling tiles are in the original building addition, the two main types originally sampled and the replacement types that are the focus of this survey. All were found to be negative for the presence of asbestos.

A total of eight samples have now been collected of the sheetrock and joint compound present in various spots in this building. Three samples were collected during the April 9th survey in the men's room. Five additional samples were collected during the May 12th survey on the 1st floor; three in the lobby and two in the hallway. All samples returned as negative for the presence of asbestos.

Inspector: *Coel Schauder* License: #1336 Expires: 09/21/12

Inspector: *Roxane Schauder* License: #00189 Expires: 02/16/13

*Follow-up Limited Inspection for Asbestos Containing Materials
Greenville County Health Department - Original Building Addition
200 University Ridge
Greenville, S.C. 29601
Page Three*

TABLE I

Sample No.	Location Sampled	Material	Result
01 - 03	Lobby	Ceiling tiles	ND*
04 - 06	Lobby	Ceiling tiles	ND*
07 - 09	Lobby	Sheetrock & joint compound	ND*
10 - 11	Hallway	Sheetrock & joint compound	ND *

ND*: none detected



ASBESTOS LABORATORY REPORT

Prepared for

Environmental Testing & Management, Inc.

PROJECT: Greenville County - Health Department - Original
Bldg. Add.

CEI LAB CODE: A12-4281


DATE REPORTED: 05/21/12

TOTAL SAMPLES ANALYZED: 11

SAMPLES >1% ASBESTOS:

TEL: 866-481-1412

www.ceilabs.com



Asbestos Report Summary

By: POLARIZING LIGHT MICROSCOPY

PROJECT: Greenville County - Health Department - CEI LAB CODE: A12-4281
Original Bldg. Add.

METHOD: EPA 600 / R93 / 116 and EPA 600 / M4-82 / 020

Client ID	Layer	Lab ID	Color	Sample Description	ASBESTOS %
1		A1290929	Off-white	Ceiling Tile	None Detected
2		A1290930	Off-white	Ceiling Tile	None Detected
3		A1290931	Off-white	Ceiling Tile	None Detected
4		A1290932	Off-white	Ceiling Tile	None Detected
5		A1290933	Off-white	Ceiling Tile	None Detected
6		A1290934	Off-white	Ceiling Tile	None Detected
7	Layer 1	A1290935	White	Sheetrock	None Detected
	Layer 2	A1290935	White	Joint Compound	None Detected
8	Layer 1	A1290936	White	Sheetrock	None Detected
	Layer 2	A1290936	White	Joint Compound	None Detected
9	Layer 1	A1290937	White	Sheetrock	None Detected
	Layer 2	A1290937	White	Joint Compound	None Detected
10	Layer 1	A1290938	White	Sheetrock	None Detected
	Layer 2	A1290938	White	Joint Compound	None Detected
11	Layer 1	A1290939	White	Sheetrock	None Detected
	Layer 2	A1290939	White	Joint Compound	None Detected



ASBESTOS BULK ANALYSIS

By: POLARIZING LIGHT MICROSCOPY

Client: Environmental Testing & Management, Inc.
 P.O. Box 896
 Mauldin, SC 29662

CEI Lab Code: A12-4281

Date Received: 05-16-12

Date Reported: 05-21-12

Project: Greenville County - Health Department - Original Bldg. Add.

ASBESTOS BULK PLM, EPA 600 METHOD

Client ID Lab ID	Lab Description	Lab Attributes	NON-ASBESTOS COMPONENTS			ASBESTOS %
			Fibrous	Non-Fibrous		
1 A1290929	Ceiling Tile	Heterogeneous	40%	Cellulose	30%	None Detected
		Off-white	25%	Fiberglass	5%	
		Fibrous Bound			Perlite Paint	
2 A1290930	Ceiling Tile	Heterogeneous	40%	Cellulose	30%	None Detected
		Off-white	25%	Fiberglass	5%	
		Fibrous Bound			Perlite Paint	
3 A1290931	Ceiling Tile	Heterogeneous	40%	Cellulose	30%	None Detected
		Off-white	25%	Fiberglass	5%	
		Fibrous Bound			Perlite Paint	
4 A1290932	Ceiling Tile	Heterogeneous	40%	Cellulose	30%	None Detected
		Off-white	25%	Fiberglass	5%	
		Fibrous Bound			Perlite Paint	
5 A1290933	Ceiling Tile	Heterogeneous	40%	Cellulose	30%	None Detected
		Off-white	25%	Fiberglass	5%	
		Fibrous Bound			Perlite Paint	
6 A1290934	Ceiling Tile	Heterogeneous	40%	Cellulose	30%	None Detected
		Off-white	25%	Fiberglass	5%	
		Fibrous Bound			Perlite Paint	
7 Layer 1 A1290935	Sheetrock	Heterogeneous	15%	Cellulose	65%	None Detected
		White	<1%	Fiberglass	20%	
		Fibrous Bound			Gypsum Binder	
Layer 2 A1290935	Joint Compound	Heterogeneous			50%	None Detected
		White			50%	
		Non-fibrous Bound			Calc Carb Binder	



ASBESTOS BULK ANALYSIS

By: POLARIZING LIGHT MICROSCOPY

Client: Environmental Testing & Management, Inc.
 P.O. Box 896
 Mauldin, SC 29662

CEI Lab Code: A12-4281

Date Received: 05-16-12

Date Reported: 05-21-12

Project: Greenville County - Health Department - Original Bldg. Add.

ASBESTOS BULK PLM, EPA 600 METHOD

Client ID Lab ID	Lab Description	Lab Attributes	NON-ASBESTOS COMPONENTS				ASBESTOS %
			Fibrous		Non-Fibrous		
8 Layer 1 A1290936	Sheetrock	Heterogeneous	15%	Cellulose	65%	Gypsum	None Detected
		White	<1%	Fiberglass	20%	Binder	
		Fibrous Bound					
Layer 2 A1290936	Joint Compound	Heterogeneous			50%	Calc Carb	None Detected
		White			50%	Binder	
		Non-fibrous Bound					
9 Layer 1 A1290937	Sheetrock	Heterogeneous	15%	Cellulose	65%	Gypsum	None Detected
		White	<1%	Fiberglass	20%	Binder	
		Fibrous Bound					
Layer 2 A1290937	Joint Compound	Heterogeneous			50%	Calc Carb	None Detected
		White			50%	Binder	
		Non-fibrous Bound					
10 Layer 1 A1290938	Sheetrock	Heterogeneous	15%	Cellulose	65%	Gypsum	None Detected
		White	<1%	Fiberglass	20%	Binder	
		Fibrous Bound					
Layer 2 A1290938	Joint Compound	Heterogeneous			50%	Calc Carb	None Detected
		White			50%	Binder	
		Non-fibrous Bound					
11 Layer 1 A1290939	Sheetrock	Heterogeneous	15%	Cellulose	65%	Gypsum	None Detected
		White	<1%	Fiberglass	20%	Binder	
		Fibrous Bound					
Layer 2 A1290939	Joint Compound	Heterogeneous			50%	Calc Carb	None Detected
		White			50%	Binder	
		Non-fibrous Bound					



ASBESTOS BULK ANALYSIS

By: POLARIZING LIGHT MICROSCOPY

Client: Environmental Testing & Management, Inc.
P.O. Box 896
Mauldin, SC 29662

CEI Lab Code: A12-4281

Date Received: 05-16-12

Date Reported: 05-21-12

Project: Greenville County - Health Department - Original Bldg. Add.

ASBESTOS BULK PLM, EPA 600 METHOD

Client ID	Lab	Lab	NON-ASBESTOS COMPONENTS		ASBESTOS
Lab ID	Description	Attributes	Fibrous	Non-Fibrous	%

